## FIRE AND EMERGENCY SERVICES, ASSAM, GUWAHATI

Dated Guwahati the 31 5 2

The Principal, St. Xavier's Public School, Nichinapara, Basugaon, Dist:- Chirang, Assam.

RENEWAL OF NO OBJECTION CERTIFICATE OF INBUILT FIRE FIGHTING! FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN THE ST. XAVIER'S PUBLIC SCHOOL AT NICHINAPARA, BASUGAON, DIST:- CHIRANG, ASSAM.

With reference to your completion report under No. NII. Dated 12.04.2021 and on the basis of the inspection report submitted by Station Officer, Hemen Deks on the building as per description below at Dag No. 153, 141, 156, 142 Patta No. 230, 41, 39, 110 Mouza Sidli, (Place- Nichinapara, Basugaon, Chirang) in respect of implementation of Inbuilt Fire Fighting/ Fire Prevention/ means of escape measures as declared fit in respect of fire safety. The Fire & Emergency Services, Assam has No objection in its occupation /utilization for the purpose of SCHOOL subject to condition mentioned below.

DETAILS OF APPROVED OCCUPATION:-

GROUND FLOOR: -1. Floor area: - 3500 ft<sup>2</sup>

100

FIRST FLOOR: - 1. Floor area: - 3500 ft<sup>2</sup>

2. Purpose of utilization: - For School Purpose.

2. Purpose of utilization For School Purpose.

## Details of Fire Fighting measures found in working condition:

- 1. Hose Reel Hose system
- Manually Operated Electric Fire Alarm system
- 3. Fire Extinguishers- 14 Nos.
- 4. Torrace Water Tank

5. Fire Pump

Deputy Director.

for and on behalf of Director of Fire and Emergency Services, Assam, Guwahati.

Dated Guwahati the

NO. F&ES/FPW/ Copy to:-

1. The Deputy Commissioner, Chirang, Assam for information and necessary action

2. The Chairman, Kajalgaon Town Committee, Assam for information and necessary action.

3. The Station Officer, Kajalgaon F&ES Station, for information.

Deputy Director, for and on behalf of Director of Fire and Emergency Services, Assam, Guwahati

## CONDITION:-

- 1. The N.O.C. is valid up to: 31.03.2022.
- 2. There should not be any change of Trade for which this License has been issued.
- There should not be any structural change in the building either horizontally or vertically. There should not also be any change in the existing arrangements.
- 4. The Fire Fighting equipments should be in serviceable condition at all time.
- 5. Water reservoir should always be kept full up to brim.
- The entrance and exit and the water reservoir should always be free from any obstruction/ projection.
- The N.O.C. is liable to be cancelled if the premises (for which the N.O.C. is granted) when inspected are not found conforming to the description and condition under which this N.O.C. is granted.

Deputy Director, for and on behalf of

Director of Vire and Emergence

La Savina

Manager

Principal